



Consulate of the United States of America

Fukuoka, Japan

April 6, 2021

First Set of Questions and Answers

Request for Quotations No. 19JA25-21-0063
HVAC Replacement Services for U.S. Consulate Fukuoka

Question 1:

"According to the technical discussion, although we will try the best to find AC unit that is most suitable we consider, we expect new AC unit in Japan market will create the same level of noise as the current unit. We expect it may need architectural discussion . May we propose as noise issue to be discussed separately from this replacement work?"

Answer 1:

The goal of this RFQ is to mitigate the noise level of the HVAC units. The solution provided by the contractor must provide all necessary equipment, installation, and other modifications, architectural or otherwise, needed to meet the requirements of the RFQ.

Question 2:

"According to the technical discussion , we consider the current vibration from the existing AC system are already mitigated as much as possible with the anti-vibration base for the wooden architecture. It is meaning we consider new AC units will create the same vibration level. Similar to above , it will need architectural discussion , we consider. Therefore, may we consider the issue of vibration separately discussed from the AC replacement work?"

Answer 2:

The goal of this RFQ is to mitigate the noise level of the HVAC units. The solution provided by the contractor must provide all necessary equipment, installation, and other modifications, architectural or otherwise, needed to meet the requirements of the RFQ.

-End of First Set of Questions and Answers-